



# **Tri-Zone Dimming Controller**

## **Models: ELED3 and ELED3H**

### **Configuration Guide**

Part Number: 8189M2410 Rev.A

Released: 2022-10

To view a list of Echoflex trademarks and patents, go to [echoflexsolutions.com/ip](https://echoflexsolutions.com/ip). All other trademarks, both marked and not marked, are the property of their respective owners.

Echoflex intends this document, whether printed or electronic, to be provided in its entirety.

# Table of Contents

Introduction .....	1
Features .....	1
Document Conventions .....	2
Help from Technical Services .....	2
Configuration Options .....	3
Simple Tap Instructions .....	3
Radio Communications .....	3
Repeater Function .....	3
Status Message .....	4
Radio Range Confirmation .....	4
Dimming Outputs .....	4
Near-Cross Technology .....	4
Switch Operation .....	5
Timed Switches .....	5
Occupancy-Based Lighting Applications .....	5
Occupancy Sensor Auto-OFF Timer .....	5
Save State .....	6
Grace Timer .....	6
Dual Technology Occupancy Sensors .....	6
Occupancy Sensors and Partial-ON .....	6
Occupancy Sensors and Partial-OFF .....	6
Occupancy Sensors with Switches .....	7
Open-Plan Shared Occupancy .....	7

Create a Shared Occupancy Space .....	7
<b>Hospitality Applications .....</b>	<b>8</b>
<b>Daylight Harvesting Applications .....</b>	<b>9</b>
Daylighting Control Override .....	9
Closed Loop Control .....	9
Open Loop Control .....	10
<b>Controller Presets .....</b>	<b>11</b>
<b>User Interface .....</b>	<b>12</b>
Power LED and Learn LED .....	12
Learn Button .....	12
Remote Linking Solution .....	13
Clear Button .....	13
LED Display .....	13
<b>Blink Indications .....</b>	<b>14</b>
Device Count Codes .....	14
Linking Activities .....	14
<b>Compliance .....</b>	<b>15</b>
FCC Compliance .....	15
ISED Compliance .....	15
Conformité ISDE .....	15


# Introduction

---

The Tri-Zone Dimming Controller is a fully configurable and complete stand-alone dimming and lighting controller designed to perform common lighting control applications based on input from wireless linked sensors and switches.

It includes 0–10 volt dimming channels for three individual dimming zones and a robust 20 A relay (16 A relay in ELED3H model) for ON/OFF control of large controlled spaces.

Echoflex controllers include functionality to allow the presetting of lighting scenes based on values for intensity and color temperature. Presets can be activated from scene stations, time clocks, or gateways. The lockout feature allows time clocks to schedule a controller's response to specific sensors or stations.



The controller supports both open or closed loop photo sensors assigning two channels as daylighting channels. The primary daylighting channel includes a set point while the secondary channel uses an offset from the set point, both configurable.

The primary daylighting channels set point can be configured based on the outdoor light in the space. The secondary channel will lag the primary channel by the offset value, providing consistent dimming results across the space as the natural light changes. The third dimming channel can be controlled by linked occupancy sensors, switches or gateway commands.

This guide describes the features of the Echoflex Tri-Zone Dimming Controller models and how to use and configure them.

## Features

- Three-zone control with 0–10 V dimming and relay switching
- Configurable presets support lighting scenes
- Accepts 120–277 VAC (regular model) or 240–347 VAC (“H” model) power input
- Integrated daylight harvesting control on two channels
- Occupancy based lighting controls with Partial- ON/OFF or manual ON, auto-OFF using wireless occupancy sensors
- Range Confirmation allows optimal placement of linked sensors
- Pre-commissioning available when sold as a system through Echoflex
- Central command support for Building Energy Management Systems (BEMS) gateway control
- Easy installation on electrical junction boxes with 1/2 in mounting nipple
- Doubles as a message repeater
- Energy code compliance including demand response, Partial-ON and Partial-OFF control



**Note:** For information about Garibaldi Pro software or pre-commissioning services that provide complete system solutions (linked and configured), contact Echoflex. Garibaldi Pro software is available for download from the Echoflex website at [echoflexsolutions.com](http://echoflexsolutions.com).

## Document Conventions

Echoflex's user documentation is designed for print or electronic use. Cross-references highlighted in this document are links to the referenced section of the guide.

Configuration parameters are emphasized in *italics*. Switch actions (ON/OFF) and dimmer events (lights ON/OFF) are emphasized in ALL CAPS. Buttons are emphasized in **[Bold Bracket]**.

This document uses the following conventions to draw your attention to important information.



**Note:** *Notes are helpful hints and information that is supplemental to the main text.*

---



**CAUTION:** *A Caution statement indicates situations where there may be undefined or unwanted consequences of an action, potential for data loss or an equipment problem.*

---



**WARNING:** A Warning statement indicates situations where damage may occur, people may be harmed, or there are serious or dangerous consequences of an action.

---



**WARNING: RISK OF ELECTRIC SHOCK!** This warning statement indicates situations where there is a risk of electric shock.

---

Please email comments about this manual to: [TechComm@etcconnect.com](mailto:TechComm@etcconnect.com).

## Help from Technical Services

If you are having difficulties that are not addressed by this document, contact Echoflex support at [service@echoflexsolutions.com](mailto:service@echoflexsolutions.com) or the main website at [echoflexsolutions.com](http://echoflexsolutions.com). If none of these resources are sufficient, contact Technical Services directly at the office identified below.

When calling for help, take these steps first:

- Prepare a detailed description of the problem
- Go near the equipment for troubleshooting
- Find your notification number if you have called in previously

## Technical Services

3031 Pleasant View Road  
Middleton, WI 53562  
800-775-4382 (USA, toll-free)  
+1-608 831-4116  
[service@echoflexsolutions.com](mailto:service@echoflexsolutions.com)

# Configuration Options

---

The controller provides dimming and switching control using input received from compatible Echoflex devices. It operates based on:

- Ambient light levels monitored by a wireless photo sensor
- Occupancy state monitored by a wireless occupancy sensor
- Switch action from a wireless wall or keycard switch
- Gateway and TimeClock control implementing scheduled or other events

This document describes the controller's features and explains how to use and configure them with Simple Tap. Some features can only be configured using Garibaldi Pro software.



**Note:** For information about Garibaldi Pro software or pre-commissioning services that provide complete system solutions (linked and configured), contact Echoflex. Garibaldi Pro software is available for download from the Echoflex website at [echoflexsolutions.com](http://echoflexsolutions.com).

---

## Simple Tap Instructions

Simple Tap is a manual method of changing individual settings one at a time. There are no tools required, simply use your finger to activate the sensors and switches linked to the controller. The tap in Simple Tap means a quick press on a sensor's **[Teach]** button and/or a switch's ON/OFF.

If the sensor is linked to multiple controllers and you do not want to make changes to all, turn off the controllers lights/loads to ignore the Simple Tap changes.

## Radio Communications

The ELED3(H) controller is equipped with a 902 MHz radio capable of transmitting and receiving wireless messages. The controller supports single-hop and dual-hop message repeating and controller status broadcast.

### Repeater Function

The repeater function repeats received messages if:

- The message has not been repeated previously
- In the case of dual-hop repeating, the messages have been repeated previously only once

If single-hop or dual-hop repeating is needed, the repeater function can be enabled/disabled using Simple Tap instructions.

1. Press and hold the **[Clear]** button on the controller.
2. Tap the **[Learn]** button:
  - Once to **disable** repeating
  - Twice to **enable** single-hop repeating
  - Three times to **enable** dual-hop repeating
3. Release the **[Clear]** button. The Power and Learn LEDs blink the corresponding number of **[Learn]** button presses.

## Status Message

The controller can broadcast a message per EEP: A5-11-01 Status Feedback Message. A message broadcasts every 100 seconds. The status message can be enabled/disabled using Simple Tap instructions.

1. Press and hold the **[Learn]** button on the controller.
2. Tap the **[Clear]** button once to **disable**, twice to **enable**.
3. Release the **[Learn]** button. The Power and Learn LEDs blink the corresponding number of **[Clear]** button presses.

## Radio Range Confirmation

Echoflex sensors that are equipped with patented Range Confirmation technology work with ELED3(H) controllers to facilitate optimal sensor placement. The Range Confirmation test is invoked at the sensor. It must be linked to the controller and during the test, any repeaters in the controller's vicinity must be disabled. The controller receives a unique message from the sensor, evaluates the signal strength and sends back a unique message containing the strongest signal value received. The sensor displays this value using color LEDs.

See the related device documentation to verify support for radio Range Confirmation testing and for test details.

## Dimming Outputs

The controller's dimming outputs provide linear, proportional dimming control of a dimming driver or ballast.

- *Output maximum level* - the high level trim of the dimming output, set to 100% by default
- *Output minimum level* - the low level trim of the dimming output, set to 10% by default

Garibaldi Pro software is required to configure the maximum and minimum levels and to disable dimming output for immediate control.

## Near-Cross Technology

The controller monitors the AC voltage waveform to prevent carbon build-up on contacts and ensure long relay life. The relay will open or close only when the waveform is close to zero.

# Switch Operation

---

The controller operates with single, dual-paddle wall, wave, and hand-held Echoflex switches as well as button station transmitters including the Multi-Button Interface (MBI) Switch Station and the Multi-Scene Station (MSS). A switch can be linked to a single channel or all the channels. Garibaldi Pro software is required to configure all the fade control settings.

- Press ON to increase the lights to the last manually set dimming level.
- Double-press ON to increase the lights to the *output maximum level*.
- Press OFF to decrease the lights to the *output minimum level* and then turns the lights off.
- Double-press OFF to turn the lights off.

Echoflex switches can also be used as dimmers when *dimming output* is enabled.

- Press and hold ON to increase to the maximum dimming level.
- Press and hold OFF to decrease to the minimum dimming level.

If a photo sensor is linked to the dimming channel it will have control priority over manually dimming the output towards the maximum output value.

## Timed Switches

The controller can be configured to make any linked wall switch station into a timed switch. Switching the lights ON starts the countdown timer for the configured period. One minute before the timer expires and the lights turn off, the lights blink once as a warning (Flick-Warn). Switching the lights ON at anytime resets the timer. Switching the lights OFF clears the timer. Garibaldi Pro software is required to configure the period for a timed switch. Each channel can be configured with it's own timer period.

# Occupancy-Based Lighting Applications

---

When occupancy sensors linked to the controller do not detect motion, they send a vacancy message to the controller. After the *occupancy auto-OFF timer* expires, the controller turns the lights OFF or fades to a preset level. For information about coordinated control of a space, see [Open-Plan Shared Occupancy on page 7](#).

## Occupancy Sensor Auto-OFF Timer

The *occupancy auto-OFF timer* is set to 15 minutes by default. The value can be changed using Simple Tap. Dual Tech sensors also have a built-in independent *occupancy timer auto-OFF*. To use the occupancy timer on the sensor, not the controller, set the controller's occupancy timer to zero seconds.

**To set the controller's *occupancy auto-OFF timer* value:**

1. Turn the light ON.
2. Tap the **[Teach]** button on the sensor three times to edit the timer period, or to set it to zero seconds. The light ramps up to full ON and then dims to OFF to acknowledge the input.

Taps	Occupancy Sensor Timer	Light Response
3 taps	0 seconds	1 blink

3. Set a number of minutes for the timer period. Tap the **[Teach]** button the number of times indicated in the table below to set the timer period. The light responds a number of times to confirm the change and then returns to normal operation.

Taps	Occupancy Sensor Timer	Light Response
1 tap	5 minutes	2 blinks
2 taps	10 minutes	3 blinks
3 taps	15 minutes	4 blinks
4 taps	20 minutes	5 blinks
5 taps	25 minutes	6 blinks

## Save State

The controller saves its current operating state every ten minutes so when power is cycled, it returns to the last saved values. The *save state* function can be overridden with a value used to recall a particular dimming output value after a power cycle. Garibaldi Pro software is required to configure overrides.

## Grace Timer

The occupancy sensor *grace timer* is a short period of time during which the controller returns the lights to the previous occupied state if triggered by motion, or audio in the case of Dual Tech sensors. The *grace timer* starts counting down after the *occupancy auto-OFF timer* has expired, providing a time period for an undetected occupant to signal that the space is occupied. Garibaldi Pro software is required to configure the *grace timer*. The default is 30 seconds.

## Dual Technology Occupancy Sensors

Dual Tech sensors have built-in occupancy timers that manage the transition from occupied to vacant state. To allow the Dual Tech sensor to control the vacancy action, the controller's *occupancy sensor auto-OFF timer* parameter should be set to 0 seconds. See [Occupancy Sensor Auto-OFF Timer on the previous page](#).

## Occupancy Sensors and Partial-ON

If only occupancy sensors are linked to the controller, the sensors automate the lights both ON and OFF. The dimming output for ON adjusts to the *occupancy partial-ON value*. The default value is 100%. It can be changed using Simple Tap.

**To set the *partial-ON value* and enable/disable *automatic partial-ON*:**

1. Use a linked switch with the light ON and dim to the target partial-ON value.
2. Press the **[Teach]** button on the sensor, and then do one of the following:
  - Press the switch ON four times to **enable** partial-ON.
  - Press the switch ON three times followed by one OFF to **disable** partial-ON.

## Occupancy Sensors and Partial-OFF

If the application requires the lights to remain ON during vacant periods but at a dimmed level, set the *vacancy partial-OFF value* using Simple Tap. The default value is 20%.

To set the *partial-OFF value* and enable/disable *automatic partial-OFF*:

1. Use a linked switch with the light ON and dim to the target partial-OFF value.
2. Press the **[Teach]** button on the sensor, and then do one of the following:
  - Click the switch OFF three times followed by one ON to **enable** partial-OFF.
  - Click the switch OFF four times to **disable** partial-OFF.

## Occupancy Sensors with Switches

If switches and sensors are linked to the controller, Vacancy Sensor Mode (manual-ON, auto-OFF) is active. The controller can be configured to turn the lights ON immediately when a sensor detects motion (partial-ON). When a switch is pressed ON or OFF, the occupancy sensor's auto-off timer resets the state to occupied, which allows the lights to stay OFF when they are switched OFF (for example, a slide show presentation). See [Occupancy Sensors and Partial-ON on the previous page](#).

## Open-Plan Shared Occupancy

The open-plan shared occupancy feature provides energy saving control over large open spaces that have been segmented into zones to comply with local energy code requirements. It allows connected lighting controllers to share the occupancy state of the zone they control. Only after all the controllers in the space report a vacant state are the lights turned off at the same time.

All Echoflex controllers support open-plan shared occupancy functionality to comply with current energy savings codes.



**Note:** *Garibaldi Pro software is the ideal tool to set up your project and configure settings, or even to make edits if your project has been pre-commissioned. Garibaldi Pro is available for download at [echoflexsolutions.com](http://echoflexsolutions.com).*

---

There is no limit to the number of controllers that are connected to a shared occupancy, but each controller must be within radio range of at least one other controller to be able to send and respond to occupancy state messages.

A shared occupancy timer starts when a controller transitions from occupied to vacant. Controllers with the same shared occupancy ID that remain occupied will reset the shared occupancy timer of any controller reporting vacancy within the ID group. The vacant controllers will remain at the partial-OFF value until all controllers in the group report vacancy. For example, when one controller reports a vacant state, the lighting transitions to partial-OFF and stays at that value until all the controllers are also vacant. After the shared occupancy timer expires, the lighting for the whole space will turn off at the same time. The shared occupancy timer default is 60 seconds.

## Create a Shared Occupancy Space

A shared occupancy space is easy to create before the controllers are installed, during pre-commissioning, or manually on site if you have access to one of the controllers and the ability to activate Link mode on each of the other zone controllers in the space.

Controllers in a shared occupancy space have the same shared occupancy ID. Pressing a button sequence on one controller generates and sends a unique shared occupancy ID message that controllers in Link mode record to join and recognize the shared occupancy feature.

## Connect Controllers

You can select any controller to send a shared occupancy ID and connect other controllers. If the selected controller does not have a shared occupancy ID (default), it will generate one to send. If the controller has a shared occupancy ID, it will send the shared occupancy ID it has recorded.



**Note:** To reset a controller's shared occupancy ID to the default, zero (0), you can delete the shared occupancy ID field in Garibaldi Pro. To restore the default manually, you must reset the controller. See [Clear Button on page 13](#).

---

1. Identify one controller to send the shared occupancy ID.
2. Activate Link mode on the controllers you want to connect, using Garibaldi Pro or manually press each of the **[Learn]** buttons. Link mode times out after 60 seconds of inactivity.
3. Press and hold the **[Clear]** button and then press the **[Learn]** button four times on the sending controller. The controller sends a shared occupancy ID for controllers in Link mode to receive and record.

Alternatively, if the project is set up in Garibaldi Pro, you can copy the sending controller's shared occupancy ID field to each of the controllers in the space.

4. Ensure an occupancy sensor is linked to each zone controller.

## Configure Controller Settings

1. Set the *vacancy partial-OFF value*, if other than the default 20% is required.
2. Set the *shared occupancy timer*, if other than the default 60 seconds is required.
3. Set the *vacancy fade-OFF rate*, if other than the default two seconds is required.

# Hospitality Applications

---

Hospitality is a specific kind of occupancy-based control. When the controller is used in a hotel or dormitory setting, it is typically linked to a keycard switch station or to both an entry door sensor and an occupancy sensor.

For example, when an occupant enters a room and inserts a key card into the keycard switch station an occupancy message is sent to linked controllers to power the room. Lights can be turned ON to a level (*occupancy partial-ON*) to create a welcoming environment.

For hospitality applications that do not use key cards for room access, an entry door sensor and occupancy sensor combination can be linked to the controller to confirm occupancy and therefore proper control. The occupancy sensor is used to monitor occupancy, not to turn lights OFF. Each time the door is opened and closed and the sensor detects motion, the room locks into an occupied state. If the door opens and closes, but no motion is detected before the *occupancy auto-OFF timer* expires, the room resumes an unoccupied state. If an occupancy message is sent when the room is in an unoccupied state, the room will lock into an occupied state until the entry door opens and releases the lock.



**Note:** If using the manual method to link a Magnetic Contact Sensor (MC-31) as a entry door sensor, link the sensor to the controller with the magnet placed next to the sensor (closed door position). If the magnet is not beside the sensor (open position), the MC-31 is linked as a window sensor.

---

Garibaldi Pro software is required to configure all the fade control settings.

# Daylight Harvesting Applications

---

Based on the ambient light level in the space, the controller modulates light intensity from lighting fixtures on the primary and secondary daylighting channels, Channel 1 and 2 respectively. The daylight harvesting application does not affect the relay operation.

When daylighting is active and is driving the two outputs, a switch, gateway command or occupancy sensor cannot force the light level higher. However, a switch, occupancy sensor, or gateway command can override the light OFF or dim to a level below the daylighting control value.

The fixtures closest to the natural light source must be connected to Channel 1, the primary daylighting channel. If the space has a secondary daylighting zone, the fixtures in the zone must be connected to Channel 2, the secondary daylighting channel. Channel 3 does not perform any daylighting routine.



**Note:** *The controller only supports one linked photo sensor.*

---

Daylight harvesting does not affect the operation of wall switches or occupancy sensors when the light is ON. If the light is ON, either a switch or occupancy sensor can override with an OFF action or dim to below the daylighting control value. See [Photo Inhibit on page 1](#).

## Daylighting Control Override

The open or closed loop daylighting features can be temporarily overridden by enabling the *daylighting manual override* parameter. The override has a timer that releases the override once expired and daylighting control resumes.

If the override is enabled, a switch can turn lights ON and manually set the dimming level.

Garibaldi Pro software is required to configure both the *daylighting manual override timer* and *daylighting manual override enable* parameters.

## Closed Loop Control

Closed loop daylighting becomes active when a photo sensor with a maximum detectable range of light less than 2500 lux is linked to the controller. In closed loop daylighting, the sensor indirectly monitors the controlled light output from the fixtures plus some of the natural light contribution.

When the lights are on, closed loop daylighting tries to maintain a given set point level within the space. This level is specified in the *closed loop daylighting set point* parameter. The controller only adjusts the dimming output on received photo sensor messages and only when the light is ON. If the light is OFF, closed loop daylighting is ignored.

To set the *closed loop daylighting set point* using Simple Tap, a photo sensor with monitoring range less than 2500 lux and a switch must be linked to the controller.



**Note:** *This process is best performed when there is little or no natural light; either close the blinds or complete this step at night.*

---

1. Turn the light ON.
2. Use a handheld photometer to measure the light on the task plane and press the fixture's switch to adjust its light level until it matches the target light level.

3. Tap the **[Teach]** button on the mounted sensor three times to set the daylight harvesting parameters to closed loop function. The light ramps up to full ON and then dims to OFF to acknowledge the change.
4. Move away from the sensor so your shadow does not affect the light level the sensor records.

After a pause, the light responds once again when the next message from the sensor is received and the controller returns to normal operation. The pause may take up to 150 seconds.

While maintaining the set point, the dimming output level only changes a small amount of the output's full range with every message received from the photo sensor. The *closed loop maximum output change* is set to 10% by default.



**Note:** *Ensure the wireless photo sensor has an update rate that is appropriate to indoor closed loop lighting applications. The period between consecutive messages should not exceed 200 seconds.*

---


The output dimming level does not change when the photo sensor level is within (+ or -) the *closed loop dead-band* value of the *closed loop daylighting set point*. Garibaldi Pro software is required to configure both the amount of change per message and the dead-band value parameters.

## Open Loop Control

Open loop daylighting becomes active when a photo sensor with a maximum detectable range of light greater than 2500 lux is linked to the controller. In open loop daylighting, the sensor monitors the natural light contribution and should be mounted so it is not affected by the controlled fixture's light output.

When the light level monitored by the photo sensor is below the *open-loop maximum output set point*, dimming output is at the *maximum output level*. When the light level is above the *open-loop minimum output set point*, dimming output is at the *minimum output level*.

In the diagram below, the solid line (blue) indicates dimming output. It begins lowering as the natural light level increases, dashed line (green). When the monitored light level is between the set points it modulates dimming output proportionally.



The rate that dimming output changes is defined by the parameter *open loop dimming rate* which defines the time for dimming to go from 0% to 100% or vice versa (default 65 seconds).

To set the *open loop maximum output set point* and *minimum output set point* using Simple Tap, a photo sensor with monitoring range greater than 2500 lux must be linked to the controller.



**Note:** *The set points are calculated as a percentage of the photo sensor's full scale range.*

1. Turn the light ON.
2. Tap the **[Teach]** button on the sensor three times. The light ramps up to full ON and then dims to OFF once.
3. Tap the **[Teach]** button the number of times indicated in the table below to set the open loop set points. The light responds the number of times tapped to confirm the change. After five seconds it returns to normal operation.

#### Sensor Range of > 2500 lux to < 11000 lux

Taps	Max. Output Set point	Min. Output Set point	Light Response
0 tap	20%	100%	1 blink
1 tap	30%	100%	2 blinks
2 taps	40%	100%	3 blinks
3 taps	50%	100%	4 blinks
4 taps	60%	100%	5 blinks

#### Sensor Range of > 11000 lux

Taps	Max. Output Set point	Min. Output Set point	Light Response
0 tap	5%	30%	1 blink
1 tap	10%	35%	2 blinks
2 taps	15%	40%	3 blinks
3 taps	20%	50%	4 blinks
4 taps	25%	55%	5 blinks

## Controller Presets

Preset values are used to determine the dimming intensity and color temperature of different lighting scenes that are part of a designed solution made up of connected devices. A scene is a coordinated combination of controllers configured and grouped to light a space according to specific requirements. Groups, scenes, and event masking can be created in a Wireless TimeClock, and activated from a Wireless TimeClock or a scene station.

Echoflex controllers have 15 configurable presets (and one reserved for zero, or OFF). Preset values can be configured and saved to a controller using Garibaldi Pro software. Presets 1 through 8 cover a graduated range of values from full ON (100%) to OFF (0%). Presets 9 through 15 are a repetition of the values 1–7 and provide the opportunity to create custom values. A default ramp time of two seconds is given for the lighting to reach the preset value.

# User Interface

---



**Note:** *Garibaldi Pro software is the ideal tool to set up your project and configure settings, or even to make edits if your project has been pre-commissioned. Garibaldi Pro is available for download at [echoflexsolutions.com](http://echoflexsolutions.com).*

---

Two buttons on the controller can be used to activate features and set specific configurations directly on the device. Two LEDs beside the buttons provide feedback about stored information and activities.

## Power LED and Learn LED

The Power and Learn LEDs can display red, green, or blue. LED color and combinations indicate which of the channels is providing device count information via blink codes or feedback for other activities.

Each channel can support occupancy sensors, switches, or gateway commands. A photo sensor can be linked to Channel 1 for daylighting with a set point, or to Channel 2 for daylighting with an offset from the set point.

- Red (Channel 1): primary daylighting with set point.
- Green (Channel 2): secondary daylighting with offset from set point.
- Blue (Channel 3): occupancy sensors, switches, or gateway commands. No photo sensor (non-daylighting).

## Learn Button

The **[Learn]** button initiates Link mode for manually linking compatible Echoflex devices to the controller's channels. See the relevant switch or sensor documentation for information on linking. Link mode times out after 60 seconds of inactivity.



**Note:** *The manual linking process can be used both to link a device to a controller and to unlink a linked device from a controller.*

---

Devices can be linked to a controller manually, using Garibaldi Pro, or during the Echoflex pre-commissioning process.

### To link a device:

1. Press the **[Learn]** button to activate Link mode. The Learn LED turns ON and the Power LED blinks. Do one of the following:
  - To link a wall switch, press the switch paddle ON three times.
  - To link a sensor, press the sensor's **[Teach]** button. Refer to the sensor's documentation for more information.

The Power LED remains lit for four seconds while it links the new device, then resumes toggling. You can link up to 20 devices to the controller.

## Remote Linking Solution

Use the following method to link the first switch if you cannot access the **[Learn]** button on a controller that has not been pre-commissioned and you do not have Garibaldi Pro software.

This method only works if there are no switches linked to the controller. You cannot link a scene station using this method.

1. Ensure you are within wireless range of the controller and have a wireless paddle switch.
  - a. If the controller has a linked sensor, you must press the **[Teach]** button on the sensor and complete step 2 within 60 seconds.
2. Click the switch paddle ON three times, OFF three times, and ON three times quickly, for a total of nine consecutive clicks. The relay will toggle and the Power LED will indicate the switch is linked.

## Clear Button

The **[Clear]** button can be used to reset the controller either to its pre-commissioned state or to its factory default state.

### To reset to pre-commissioned state:

1. Press and hold the **[Clear]** button until the red Power and green Learn LEDs start blinking.
2. Release the **[Clear]** button. The LEDs repeat a blink code by color to indicate the type and number of devices linked to each channel at pre-commissioning.

### To reset to factory default state:

1. Press and hold the **[Clear]** button until the red Power and green Learn LEDs start blinking, and continue to hold for 15 seconds until the LEDs stay on solid.
2. Release the **[Clear]** button. The Power LED displays solid red to indicates factory default state.

## LED Display

The LEDs are enabled by default. They can be disabled by adjusting a configuration parameter using Garibaldi Pro software. If disabled, the LEDs are only lit for the configured time when a controller button is pressed, when in Link mode, or if the remote management *Action* command is used to toggle the light.

# Blink Indications

The tables below describe the LED codes that identify linked devices and the LED indications that describe linking activities. A different color LED identifies each channel. Red is for Channel 1, Green is for Channel 2, and blue is for Channel 3.

## Device Count Codes

The following codes provide a visible report of the devices that are linked to the controller. The Power LED repeats a code of blinks that represent the type and number of linked devices. Long blinks = type. Short blinks = count. If the controller does not have any linked devices, the Power LED remains on solid.

Device Type	Power LED	Learn LED
Switches	<b>1 long blink</b> followed by short blinks that count the switches	Off
Occupancy sensors *	<b>2 long blinks</b> followed by short blinks that count the sensors	Off
Photo sensor † (maximum of 1)	<b>3 long blinks</b> followed by short blink that counts the sensor	Off
Gateways and TimeClocks	<b>4 long blinks</b> followed by short blinks that count the devices	Off
Demand response	<b>5 long blinks</b> followed by short blinks that count the devices	Off
Entry door sensors	<b>6 long blinks</b> followed by short blinks that count the sensors	Off
Window sensors	<b>7 long blinks</b> followed by short blinks that count the sensors	Off
Keycard switches	<b>8 long blinks</b> followed by short blinks that count the switches	Off

\* An occupancy sensor linked to any channel will appear to be linked to all three channels.

† A photo sensor linked to CH1 or CH2 will appear to be linked to both channels.

## Linking Activities

Activity	Power LED	Learn LED	Light Response
Link mode	Blinking	On solid	Cycles ON and OFF
Store link ID	On for 4 seconds, and then blinking	On solid	ON for 4 seconds, and then cycles
Clear link ID	Off for 4 seconds, and then blinking	On solid	OFF for 4 seconds, and then cycles

# Compliance

---

For complete regulatory compliance information, see the Echoflex Tri-Zone Dimming Controller datasheet at [echoflexsolutions.com](http://echoflexsolutions.com).

## FCC Compliance

Echoflex Tri-Zone Dimming Controller

(For any FCC matters):

Echoflex Solutions, Inc.

3031 Pleasant View Road

Middleton, WI 53562

+1 (608) 831-4116

[echoflexsolutions.com](http://echoflexsolutions.com)

This device complies with Part 15 of the FCC Rules. Operation is subject to the following two conditions: (1) this device may not cause harmful interference, and (2) this device must accept any interference received; including interference that may cause undesired operation.

This equipment has been tested and found to comply with the limits for a Class A digital device, pursuant to Part 15 of the FCC rules. These limits are designed to provide reasonable protection against harmful interference when the equipment is operated in a commercial environment. This equipment generates, uses, and can radiate radio frequency energy and, if not installed and used in accordance with the instructions, may cause harmful interference to radio communications. Any modifications or changes to this product not expressly approved by Electronic Theatre Controls, Inc. could void the user's authority to operate the product. Operation of this equipment in a residential area is likely to cause harmful interference, in which case the user will be required to correct the interference at their own expense.

Contains FCC ID: SZV-STM300U

## ISED Compliance

This device contains a license-exempt transmitter/receiver that complies with Innovation, Science, and Economic Development Canada's license-exempt RSSs. Operation is subject to the following two conditions:

1. This device may not cause interference.
2. This device must accept any interference, including interference that may cause undesired operation of the device.

Contains IC ID: RSS 210

## Conformité ISDE

Cet appareil contient un émetteur/récepteur conforme aux CNR d'Innovation, Sciences et Développement économique Canada (ISDE) applicables aux appareils radio exempt de licence. Son fonctionnement est soumis aux deux conditions suivantes:

1. L'appareil ne doit pas produire d'interférences.
2. L'utilisateur de l'appareil doit accepter toute interférence, même si l'interférence est susceptible d'en compromettre le fonctionnement.

Contient ID IC: RSS 210









